



**SIGNATURER:**

**P** = CIRKULATIONS-PUMPE

**S** = SHUNTVENTIL

MIT BUD ER, AT VENTILEN  
BLANDER VARMT VAND I  
RETURVANDET FOR AT SIKRE,  
AT DETTE IKKE ER FOR KOLDT