

### Udsugning:


krøken =  $71 \text{ m}^3/\text{h}$

L-bad =  $50 \text{ m}^3/\text{h}$

S-bad =  $52 \text{ m}^3/\text{h}$

Bruggers =  $44 \text{ m}^3/\text{h}$

Ialt =  $217 \text{ m}^3/\text{h}$



### Indblæsning:

stue =  $59 \text{ m}^3/\text{h}$

Soveri =  $36 \text{ m}^3/\text{h}$

Vaerlse =  $31 \text{ m}^3/\text{h}$

— =  $30 \text{ m}^3/\text{h}$

— =  $30 \text{ m}^3/\text{h}$

— =  $32 \text{ m}^3/\text{h}$

Ialt =  $218 \text{ m}^3/\text{h}$

